Installation Requirements for Commercial Electricity Meters and Distribution Boxes



Overview

When a single set of service entrance conductors supply a multi-meter installation, numbering from two to six meters, a main switch for each meter shall be located on the load side of each meter.

Key Takeaways

Commercial electricity meters and distribution boxes must be installed in accessible, safe, and code-compliant locations, with proper space allocation, mounting, and protection according to local and international standards.

Meter Installation Requirements

Location and Environment: Meters should be installed in clean, dry, and accessible locations, protected from weather, mechanical damage, vibrations, extreme temperatures, and dampness. Indoor installations are preferred for safety and maintenance purposes, and the metering point should be as close to the origin of the supply as practicable (HK Electric guidance). Meter Types: Single-phase LV installations: Whole current (direct connected) meters.

Three-phase L

V installations: For main switch ratings ≤100 A, whole current meters; for >100 A, CT-operated meters. High-voltage installations (11 kV/22 kV): Transformer-operated meters installed in substations with meters inside the customer's switchroom. Half-hourly meters: Required if maximum demand exceeds 100 kW; optional for 70–100 kW.

© 2026 CGWEB NETWORK INFRASTRUCTURE - All rights reserved

Seals and Certification: Meter seals must not be tampered with, and meters should be certified and periodically checked for accuracy.

Distribution Box and Panelboard Requirements

Space and Clearance: Panelboards must have a minimum working space of 30 inches (762 mm) wide, 36 inches (914 mm) deep, and 6. 5 feet (≈2 m) high in front of the panel. The mounting height should not exceed 6 ft 7 in (2 m) from the floor.

Dedicated electrical space from floor to 6 ft (1. 8 m) is required, and no equipment should extend more than 6 inches beyond the panel front. Accessibility: Panels must be readily accessible, with doors opening fully to 90°, and the working space must remain clear of obstructions or storage.

C

T and Protection Requirements: Over-current and earth fault CTs should meet class 10P20 and 15 VA rating. For multi-transformer supplies, 4-pole circuit breakers of at least 1600 A with mechanical and electrical interlocks are required to prevent backfeed. Meter Enclosure Space: UK guidance (ENA EREC G87) recommends sufficient space within meter enclosures for whole current metering, with allowances for smart meters, three-phase intakes, and additional equipment like isolating switches or small consumer units.

DN

Os may provide specific space requirements in connection offers.

Professional Installation

Meters and distribution boxes must be installed by registered and qualified technicians. Unauthorized installation is illegal and unsafe due to the high risk of electrical hazards.

The MPA

N (Meeting Point Administration Number) is required for supplier identification during installation.

Summary

To comply with commercial electricity installation standards: Choose the correct meter type based on phase, voltage, and demand. Install meters and distribution boxes in accessible, protected, and code-compliant locations. Maintain proper clearances, working space, and mounting heights.

© 2026 CGWEB NETWORK INFRASTRUCTURE - All rights reserved

Ensure C

Ts, breakers, and protective devices meet regulatory specifications. Engage qualified professionals for installation and maintenance. Following these guidelines ensures safety, accurate billing, and compliance with local and international electrical codes.

Article Content

ELECTRIC SERVICE REQUIREMENTS REVISION PAGE

When a single set of service entrance conductors supply a multi-meter installation, numbering from two to six meters, a main switch for each meter shall be located on the load side of each meter.

The installation requirements for the distribution box

IntroductionUnderstanding The Components of A Distribution BoxSelecting The Right Distribution BoxSite Preparation and Location RequirementsElectrical Connections and WiringCompliance with Standards and RegulationsConclusionProper installation of a distribution box isn''t just a technical requirement. It''s a vital step in ensuring the safety and efficiency of your entire electrical system. Following best practices reduces the risk of electrical fires, power outages, and other hazards, protecting your property and keeping everyone safe. If you''re looking for a reliable,...See more on eabel Published: Feb 7, 2025switchpal

A Guide to Commercial Electricity Meter Installation

Learn about commercial electricity meter installation: the process, benefits for your business, and how the right meter can reduce energy costs.

Guidance on installing equipment within meter enclosures | NICEIC

The experts at NICEIC provide more detail on the installation of equipment in meter boxes. Electrical equipment associated with the consumer''s electrical installation is increasingly

Service and Meter Requirements

Contracts for the electrical installation should include the requirement that all electrical wiring and apparatus conform with the requirements of applicable governmental codes, as well as the standards

Electric Service Guidelines

In addition to the National Electrical Code, National Electrical Safety Code, and state and local building codes, MTE has installation requirements which must be followed.

Metering

© 2026 CGWEB NETWORK INFRASTRUCTURE - All rights reserved

We set rules suppliers must follow to install and maintain energy meters so that customers can monitor their usage and get accurate bills.

ADDC Guidelines for Smart Meter Installation (Rev)

The scope of these guidelines is to accept and ensure that all electricity and water meter installation requirements are met for installing the meter in accordance with the ADDC standard and regulations.

Meter Installation and Specification Handbook Version 1

3.2 The Member shall maintain, without cost to HEC, sufficient and proper facilities for the installation of meters and other apparatus at an easily accessible location on or within the premises to be supplied

Requirements And Specifications For Installation Of Distribution Boxes ...

In flammable and explosive environments, explosion-proof distribution boxes should be selected and explosion-proof treatment should be carried out. The installation of explosion-proof

Reuters | Breaking International News & Views

Find latest news from every corner of the globe at Reuters , your online source for breaking international news coverage.

METER ROOM_RE M final lastlast

Mainly the meters shall be installed in the Inside Room Fiberglass Reinforced Polyester Meter Box according to SEC spec. No. 42-SDMS-03 latest revision for any group of KWH meters installation.

ADDC Guidelines for Smart Meter Installation (Rev)

Install a 25mm dia PVC conduit (Heavy grade 1250N compression force) vertically between the floor-to-floor electricity meter rooms for interconnecting communication cables and provide a 150x150mm

ComEd Proper Metering Installation Booklet_FINAL

This booklet contains some of the most common metering equipment installation examples. The illustrations depict “Acceptable” and “Not Acceptable” metering configuration installations. Improper

Electrical

Working with electricity can be dangerous. Engineers, electricians, and other professionals work with electricity directly, including working on overhead lines, cable harnesses, and circuit assemblies.

© 2026 CGWEB NETWORK INFRASTRUCTURE - All rights reserved

The installation requirements for the distribution box

A distribution box is the heart of any electrical system. It takes the incoming power and safely distributes it to different circuits throughout your

How to Install an Electric Meter Box Safely

An electric meter box protects the utility meter, service entry, and connection point between the power supply and the building. A correct

Metering guidelines.cdr

If consumer is installing panels for multiple meters installation, standard panel sizes should be of following sizes for 1 phase, 3 phase & CT meters (single meter size) respectively.

S-E-03—Specification for the installation and use of electricity meters ...

4.3 Self-contained meters 4.3.1 The operating voltage rating of the meter installed must have a marked voltage rating that is between 90% and 105% of the service voltage at the meter installation site.

Related Video Reference

This video was associated with the source search result. Verify technical details against current product documentation and project requirements.

Contact Us

Continue your research online:

Website: https://cgweb.co.za
Technical inquiry: https://cgweb.co.za/project-enquiry.html

This document is for preliminary research. Verify specifications against current standards, product documentation and project requirements.

© 2026 CGWEB NETWORK INFRASTRUCTURE - All rights reserved